

Town of Whitchurch-Stouffville - Stouffville DWS
Drinking Water Systems Regulation O. Reg. 170/03 Section 11 Reporting

***MODIFIED* OPTIONAL ANNUAL REPORT TEMPLATE**

Accessible formats or communication supports are available upon request.

Drinking-Water System Number:	260003162
Drinking-Water System Name:	Stouffville Drinking Water System
Drinking-Water System Owner:	Town of Whitchurch-Stouffville
Drinking-Water System Category:	Large Municipal Residential, Class 1
Period being reported:	January 1, 2021 to December 31, 2021

The Stouffville Drinking Water System serves more than 10,000 people.

This annual report is available to the public at no charge on the Town's web site and upon request.

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection:

Town of Whitchurch-Stouffville

111 Sandiford Drive

Stouffville, ON L4A 0Z8

www.townofws.ca/en/residents/water-quality.aspx

No additional Drinking Water System owners that are connected to and receive drinking water from the Town of Whitchurch-Stouffville.

System users were notified that Stouffville's annual report is available free of charge by public access and notice through:

- Web
- Public Request at any time

Town of Whitchurch-Stouffville - Stouffville DWS

Drinking Water Systems Regulation O. Reg. 170/03 Section 11 Reporting

Description of the Stouffville Drinking Water System

About Stouffville

Water treatment and supply for the Stouffville Water Distribution System is the responsibility of the Regional Municipality of York. Water supply is comprised of a combination of ground water production wells and surface water which originates at Lake Ontario. The combination of surface and well water supplies creates a blended water supply for the Community of Stouffville. Water treatment for each of these sources is provided by the Region by means of chlorination. Currently the Region owns, operates and maintains in accordance with MECP requirements the following: five ground water production wells at three sites, two ground level reservoirs, two elevated storage tanks and approximately seven kilometers of transmission watermain. For further information regarding water supply and treatment, contact the Regional Municipality of York located at 17250 Yonge Street, Newmarket Ontario, L3Y 6Z1 or visit their website at www.york.ca.

The Town of Whitchurch-Stouffville owns and operates the Stouffville Water Distribution System, servicing approximately 35,000 residents and businesses in the community of Stouffville and for approximately 20 households on Highway 48.

This water distribution system infrastructure consists of approximately 145 kilometers of various size watermains, 1650 watermain valves, 1150 hydrants and 46 sampling stations.

The operation and maintenance of this system to ensure safe drinking water is the responsibility of the Town's Public Works Department. Staff are certified in accordance with the Ministry of the Environment, Conservation and Parks of Ontario (MECP) requirements. In 2011 the MECP issued to the Town the Municipal Drinking Water License for the Stouffville Water Distribution System and approved the Town's Operational Plan. This plan is part of the Town's Quality Management System that describes the processes and procedures by which this water distribution system is operated and maintained. Activities generally include watermain break repairs, valve maintenance, hydrant maintenance, water locate stakeouts, watermain flushing and water quality sampling. The Operational Plan is available for review to the Public on the Town's website www.townofws.ca. A copy of the water distribution system annual and summary reports are also available on the Town's website.

List all water treatment chemicals used over this reporting period

Not applicable. Treatment chemicals are introduced at the various sources by the York Region only. Refer to the York Region website www.york.ca/drinkingwater.

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Brief description and breakdown of monetary expenses incurred

\$ 62,750 – Various watermain, valve and hydrant improvements

Town of Whitchurch-Stouffville - Stouffville DWS
Drinking Water Systems Regulation O. Reg. 170/03 Section 11 Reporting

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date and Location	Parameter	Result	Unit of Measure	Corrective Action and Result	Corrective Action Date
AWQI #154539 July 5, 2021 Norman Jones Sampling Station	Total Coliforms	P	Presence/ Absence	Flush and resample	July 6, 2021
AWQI #155074 August 12, 2021 6372 Main St Sampling Station	Total Coliforms	P	Presence/ Absence	Flush and resample	August 13, 2021
AWQI #155309 August 30, 2021 6833 Bethesda Rd Sampling Station	Total Coliforms	P	Presence/ Absence	Flush and resample	September 1, 2021

Microbiological testing done under the Schedule 10 of Regulation 170/03 during this reporting period

	Number of Distribution Samples	Range of Results (min # to max #)	Detections
E. coli	879	N/A	0
Total Coliforms	879	N/A	3
HPC	571	0 - 47	0
Raw and Treated	For raw and treated samples collected under Schedule 10, refer to the Region of York Annual Report .		

Operational testing done under Schedule 7 of Regulation 170/03 during the period covered by this Annual Report

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure	<i>NOTE: For continuous monitors use 8760 as the number of samples.</i>
Turbidity (treated)	Refer to York Region Annual Report .			
Chlorine (free)	4,718	0.06 – 2.31	mg/L	
Fluoride (If the DWS provides fluoridation)	Refer to York Region Annual Report .			

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
Not applicable				

Summary of Inorganic parameters tested during this reporting period, or the most recent result.

Parameter	Date Sampled	Result	Unit of Measure
Nitrite	October 5, 2021	<0.5	mg/L
Nitrate	October 5, 2021	1.01	mg/L
Lead (Distribution system)	July 6, 2021	<0.0005	mg/L

Town of Whitchurch-Stouffville - Stouffville DWS
Drinking Water Systems Regulation O. Reg. 170/03 Section 11 Reporting

For all other results please refer to the [York Region Annual Report](#).

Summary of Calculated Running Annual Average Trihalomethane (THM) during this reporting period

Facility monitored for THM	Stouffville DWS
Annual Average Q1-Q4	0.014 mg/L
Does result exceed Standard of 0.100 mg/L?	No

Summary of Calculated Running Annual Average Total Haloacetic Acids (HAAs) during this reporting period

Facility monitored for HAAs	Stouffville DWS
Annual Average (mg/L)	0.011 mg/L
Does result exceed Proposed Standard of 0.080 mg/L?	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
None			