

**QMS-APP-08-01**  
**Risk Assessment Outcomes**

January 26, 2021 Attendees: Brian Kavanagh, Patrick Ward, James Ainsworth, Luigi Colangelo, Matt Sullivan, Peter Wyllie

January 26, 2022 Attendees: Brian Kavanagh, Peter Pound, James Ainsworth, Jeff Thomson, Matt Sullivan, Peter Wyllie

January 27, 2023 Risk Assessment Review Attendees: Brian Kavanagh, Matt Sullivan, Jeff Thomson, Peter Wyllie, James Ainsworth, Patrick Ward, Corey Thomson

Activity or Process Step	Description of Hazardous Event	Description of Hazard	Control Measures	Monitoring Procedures	Response Procedures	Controllable (Yes /No)	Likelihood	Severity	Detectability	Total (CPP Threshold >= 7)	Critical Control Point (Yes/No)	Critical Control Limit		
<b>Drinking Water Supply</b>														
Treated Water Supply Interruption From York Region  <i>* Highway 48 system part of Stouffville WDS with no redundancy. Due to uniqueness of situation, this zone has been assessed separately</i>	York Region owns and maintains the wells, pumps, and reservoirs required for the supply of the Town's potable water.  York Region is an accredited Operating Authority and must comply with the DWQMS, including performing a risk assessment.  Failure of any of these components can create long-term adverse effects to the source, requiring York Region to stop supply on a temporary or permanent basis. Short and long-term	Microbiological: • E. Coli • Total Coliform • HPC  Physical: • Colour • Turbidity • Low pressure	No control measures by the Town.  York Region has communication protocols in place in the event of a failure.	York Region SCADA system  Resident complaints	Water restriction by-law  Isolation of distribution system  Emergency response escalation procedures  Emergency supply of bulk water (bottled, trucks, etc.)  Closing of valve VA4047 at	Ballantrae/Musselman's Lake							No	None
						No	2	4	1	7	No	None		
						Stouffville							No	None
						*Stouffville (Highway 48)							No	None

Activity or Process Step	Description of Hazardous Event	Description of Hazard	Control Measures	Monitoring Procedures	Response Procedures	Controllable (Yes /No)	Likelihood	Severity	Detectability	Total (CPP Threshold >= 7)	Critical Control Point (Yes/No)	Critical Control Limit
	adverse effects to the quantity of supply include, but are not limited to: <ul style="list-style-type: none"> <li>power failures</li> <li>equipment failure</li> <li>well levels</li> <li>scheduled &amp; unscheduled maintenance</li> <li>long-term impacts to climate change (10 years or greater)</li> <li>shortfall in water supply</li> <li>extreme weather events</li> <li>sustained extreme temperatures</li> <li>Chemical spills impacting source water</li> <li>terrorist &amp; vandalism actions</li> <li>sustained pressure loss</li> </ul>				Lakeshore affects water supply between the Region's tower and Lakeshore as there is no redundancy in the system. Region to be notified if any shutdown is required in this area.							
<b>Distribution System Infrastructure</b>												
Failure of Distribution Piping, Valves and Appurtenances	Mechanical failure of distribution system piping, valves and appurtenances can create adverse effects to water quantity and quality. Adverse effects include, but are not limited to: <ul style="list-style-type: none"> <li>long-term impacts to climate change (10 years or greater)</li> <li>shortfall in water supply</li> <li>scheduled &amp; unscheduled maintenance</li> <li>extreme weather events</li> <li>sustained extreme temperatures</li> <li>terrorist &amp; vandalism actions</li> </ul>	Routine and Unplanned repairs always pose a risk of: Microbiological: <ul style="list-style-type: none"> <li>E. Coli</li> <li>Total Coliform</li> <li>HPC</li> </ul> Physical: <ul style="list-style-type: none"> <li>Colour</li> <li>Turbidity</li> </ul> Chemical:	None	Routine inspection	MECP Disinfection Procedure Direction from York Region Health Department QMS-SOP-15-01 – Unscheduled Repairs QMS-SOP-16-02 Adverse Water Quality Reporting	Ballantrae/Musselman's Lake						
				Resident complaints		No	1	2	1	4	No	None
				Preventative Maintenance program		Stouffville						
				Lifecycle replacement		No	3	3	1	7	No	None
General observation												

Activity or Process Step	Description of Hazardous Event	Description of Hazard	Control Measures	Monitoring Procedures	Response Procedures	Risk Assessment						
						Controllable (Yes/No)	Likelihood	Severity	Detectability	Total (CPP Threshold >= 7)	Critical Control Point (Yes/No)	Critical Control Limit
	<ul style="list-style-type: none"> <li>sustained pressure loss</li> <li>Backflow</li> </ul>	<ul style="list-style-type: none"> <li>List contained in O. Reg 169/03</li> </ul>			Asset management (i.e. replacement of iron pipe)							
Distribution Piping, Valves and Appurtenances – Tuberculation and sedimentation	Tuberculation and sedimentation can create adverse effects to water quantity and quality. Adverse effects include, but are not limited to: <ul style="list-style-type: none"> <li>scheduled &amp; unscheduled maintenance</li> </ul>	Microbiological: <ul style="list-style-type: none"> <li>Biofilm</li> <li>Iron eating bacteria</li> <li>Total Coliform</li> </ul> Physical: <ul style="list-style-type: none"> <li>Turbidity</li> <li>Colour</li> <li>Solids (suspended or dissolved)</li> </ul>	None	Routine water quality sampling  Resident Complaints	Pipe cleaning (i.e. flushing, swabbing)  Asset management (i.e. replacement or rehabilitation of iron pipe)  Deviations of Critical Control Limits are recorded in the Summary of Sampling Results (by year) spreadsheet, under the CCL tab	Ballantrae/Musselman's Lake						
						Yes	4	1	3	8	Yes	Restricted flow, Discolored water
						Stouffville						
						Yes	4	1	3	8	Yes	Discolored water
Pressure Reducing Valve	Pressure reducing valves are required between Stouffville Zones 2 & 3 to ensure high pressure does not cause damage to the water distribution system or private plumbing. <ul style="list-style-type: none"> <li>scheduled &amp; unscheduled maintenance</li> <li>terrorist &amp; vandalism actions</li> <li>sustained pressure loss</li> </ul>	Physical: <ul style="list-style-type: none"> <li>Turbidity</li> <li>Colour</li> <li>Property damage (high pressure)</li> </ul>	Preventative maintenance  Lifecycle replacement	Monthly visual inspection of PRVs and Zone 3 water pressure  Annual PRV calibration and maintenance by contractor	Repair/ replacement of PRV  Deviations of Critical Control Limits are recorded in the Summary of Sampling Results (by year) spreadsheet, under the CCL tab	Ballantrae/Musselman's Lake						
						N/A						
						Stouffville						
						No	2	1	2	5	No	Pressure above 100psi

Activity or Process Step	Description of Hazardous Event	Description of Hazard	Control Measures	Monitoring Procedures	Response Procedures	Risk Assessment						
						Controllable (Yes/No)	Likelihood	Severity	Detectability	Total (CPP Threshold >= 7)	Critical Control Point (Yes/No)	Critical Control Limit
Infrastructure Commissioning (new or replacement)	Watermain commissioning can create adverse effects to water quality. Adverse effects include, but are not limited to: <ul style="list-style-type: none"> <li>terrorist &amp; vandalism actions</li> <li>Backflow</li> </ul>	Microbiological: <ul style="list-style-type: none"> <li>E. Coli</li> <li>Total Coliform</li> <li>HPC</li> </ul> Chemical: <ul style="list-style-type: none"> <li>List contained in O. Reg 169/03</li> </ul>	MECP Disinfection Procedure  New Watermain Commissioning Procedure (Town Standard)	QMS-SOP-16-01 Collection and Handling of Drinking Water Samples  Oversight by Town Licensed Operator (OIC)  New infrastructure physically separated from system	QMS-SOP-16-02 Adverse Water Quality Reporting	Ballantrae/Musselman's Lake						
						Yes	1	1	1	3	No	None
						Stouffville						
						Yes	1	1	1	3	No	None
<b>Distribution System - Operational Activities</b>												
Adverse Water Quality	Adverse water quality can be created by one or a combination of the activities outlined in this risk assessment. It can also be caused from failure of control measures and/or monitoring procedures. <ul style="list-style-type: none"> <li>long-term impacts to climate change</li> <li>shortfall in water supply</li> <li>extreme weather events</li> <li>sustained extreme temperatures</li> <li>Chemical spills impacting source water</li> <li>terrorist &amp; vandalism actions</li> </ul>	Microbiological: E. Coli Total Coliform Chemical: <ul style="list-style-type: none"> <li>List contained in O. Reg 169/03</li> <li>Loss of Chlorine Residual</li> </ul>	Water Quality Sampling and Testing	QMS-SOP-08-01 Deviations from Critical Control Points QMS-SOP-12-01 Inter-Municipal Communication Protocol  QMS-SOP-15-01 Unscheduled Repairs	QMS-SOP-16-02 Adverse Water Quality Reporting  Maximum acceptable concentration (MAC) outlined in O. Reg 169/03. Town initiates response at half the maximum acceptable concentration (MAC)	Ballantrae/Musselman's Lake						
						No	2	2	3	7	Yes	<ul style="list-style-type: none"> <li>E. Coli &amp; TC= Presence/ Absence</li> <li>List contained in O. Reg 169/03 =half the maximum acceptable concentration (MAC)</li> <li>Loss of Chlorine Residual – Low=0.4</li> </ul>

Activity or Process Step	Description of Hazardous Event	Description of Hazard	Control Measures	Monitoring Procedures	Response Procedures	Controllable (Yes/No)	Likelihood	Severity	Detectability	Total (CPP Threshold >= 7)	Critical Control Point (Yes/No)	Critical Control Limit
	<ul style="list-style-type: none"> <li>sustained pressure loss</li> <li>Backflow</li> </ul>			QMS-SOP-15-06 Water and Sewer Connections  QMS-SOP-16-01 Collection and Handling of Drinking Water Samples  QMS-SOP-16-02 Adverse Water Quality Reporting  QMS-SOP-18-01 Contamination of the Drinking Water System  QMS-SOP-18-02 Boil Water and Drinking Water Advisory  QMS-SOP-18-03 Cross Connections	Direction from York Public Health  Deviations of Critical Control Limits are recorded in the Summary of Sampling Results (by year) spreadsheet, under the CCL tab							mg/l, high = 2.1 mg/l
						Stouffville						
						No	2	2	3	7	Yes	<ul style="list-style-type: none"> <li>E. Coli &amp; TC= Presence/Absence</li> <li>List contained in O. Reg 169/03 =half the maximum acceptable concentration (MAC) Loss of Chlorine Residual – Low=0.4 mg/l, high = 2.1 mg/l</li> </ul>
Operation of Valves – Valve Position incorrect	Incorrect valve position can create adverse effects to water quality and quantity. <ul style="list-style-type: none"> <li>shortfall in water supply</li> <li>terrorist &amp; vandalism actions</li> </ul>	Microbiological: <ul style="list-style-type: none"> <li>E. Coli</li> <li>Total Coliform</li> <li>HPC</li> </ul>	QMS-FRM-15-03 - Water Shutdown Notification Information Training	QMS-FRM-15-03 - Water Shutdown Notification Information Training	QMS-SOP-15-01 Unscheduled Repairs  QMS-SOP-15-05 Valve Inspections	Ballantrae/Musselman's Lake						
						Yes	2	1	3	6	No	None
						Stouffville						
						Yes	3	2	3	8	Yes	Visual Inspections

Activity or Process Step	Description of Hazardous Event	Description of Hazard	Control Measures	Monitoring Procedures	Response Procedures	Controllable (Yes /No)	Likelihood	Severity	Detectability	Total (CPP Threshold >= 7)	Critical Control Point (Yes/No)	Critical Control Limit
				Lockout devices Valve turning/ maintenance program	Deviations of Critical Control Limits are recorded in the Summary of Sampling Results (by year) spreadsheet, under the CCL tab							
Temporary Connection to Buildings	Temporary connections to buildings due to service break or frozen service can create adverse effects to water quality and quantity <ul style="list-style-type: none"> <li>long-term impacts to climate change</li> <li>sustained extreme temperatures</li> <li>terrorist &amp; vandalism actions</li> <li>Backflow</li> </ul>	Microbiological: <ul style="list-style-type: none"> <li>E. Coli</li> <li>Total Coliform</li> </ul>	MECP Watermain Disinfection Procedure,	QMS-SOP-16-01 Collection and Handling of Drinking Water Samples	Site specific requirements	Ballantrae/Musselman's Lake						
						No	2	1	1	4	No	None
						Stouffville						
						No	2	1	1	4	No	None
Temporary Watermains	Temporary watermains for construction or emergency purposes can create adverse effects to water quality and quantity <ul style="list-style-type: none"> <li>long-term impacts to climate change</li> <li>sustained extreme temperatures</li> <li>terrorist &amp; vandalism actions</li> <li>Backflow</li> </ul>	Microbiological: <ul style="list-style-type: none"> <li>E. Coli</li> <li>Total Coliform</li> </ul>	MECP Watermain Disinfection Procedure,	QMS-SOP-16-01 Collection and Handling of Drinking Water Samples	Site specific requirements	Ballantrae/Musselman's Lake						
						No	1	3	1	5	No	None
						Stouffville						
						No	2	3	1	6	No	None
Testing and Monitoring Equipment	Failure of equipment can lead to adverse water quality. <ul style="list-style-type: none"> <li>Backflow</li> </ul>	Microbiological: <ul style="list-style-type: none"> <li>E. Coli</li> <li>Total Coliform</li> </ul>	Calibration of units by manufacturer  Redundancy	Training  verification of units by Operators	Operational Plan System Procedure QMS-SYS-17	Ballantrae/Musselman's Lake						
						Yes	1	3	1	5	No	None
						Stouffville						

Activity or Process Step	Description of Hazardous Event	Description of Hazard	Control Measures	Monitoring Procedures	Response Procedures	Controllable (Yes /No)	Likelihood	Severity	Detectability	Total (CPP Threshold >= 7)	Critical Control Point (Yes/No)	Critical Control Limit
	<ul style="list-style-type: none"> <li>terrorist &amp; vandalism actions</li> <li></li> </ul>	Chemical: <ul style="list-style-type: none"> <li>Chlorine Residual (free)</li> </ul>	Lifecycle replacement of colorimeters (5-7 years)			Yes	1	3	1	5	No	None
Labour Shortage	Shortage of Employee resources can limit the ability to fulfill regulatory requirements of O.Reg. 170/03. Can be caused by labour dispute or pandemic <ul style="list-style-type: none"> <li>Sustained pressure loss (Distribution Systems)</li> <li>Backflow (Distribution Systems)</li> </ul>	Microbiological: <ul style="list-style-type: none"> <li>E. Coli</li> <li>Total Coliform</li> </ul> Chemical: <ul style="list-style-type: none"> <li>Chlorine Residual (free)</li> </ul>	Redundancy	Labour-Management Relations  Corporate Health and Safety Policies and Procedures  Member of ONWARN	Utilize contractors retained for water quality sampling in unassumed subdivisions and emergency infrastructure repairs	Ballantrae/Musselman's Lake						
						Yes	3	1	1	3	No	None
						Stouffville						
						Yes	3	1	1	3	No	None
<b>Distribution System – Other Unclassified Hazardous Events</b>												
Unauthorized Connection to system or appurtenances	Unauthorized connections can create adverse effects to water quality and quantity <ul style="list-style-type: none"> <li>Backflow</li> <li>terrorist &amp; vandalism actions</li> </ul>	Microbiological: <ul style="list-style-type: none"> <li>E. Coli</li> <li>Total Coliform</li> </ul>	Anti-tampering devices for hydrants where needed	Resident complaints  York Region SCADA monitoring  Visual inspections	QMS-SOP-15-02 Supply of Bulk Water  QMS-SOP-18-03 Cross Connections  Water by-law 2018-054 (as amended)  Bulk water station available 24/7 with account setup	Ballantrae/Musselman's Lake						
						No	2	4	2	8	Yes	Depend on situation
						Stouffville						
						No	3	4	2	9	Yes	Depend on situation

Activity or Process Step	Description of Hazardous Event	Description of Hazard	Control Measures	Monitoring Procedures	Response Procedures	Controllable (Yes /No)	Likelihood	Severity	Detectability	Total (CPP Threshold >= 7)	Critical Control Point (Yes/No)	Critical Control Limit
					Hydrant permit system Deviations of Critical Control Limits are recorded in the Summary of Sampling Results (by year) spreadsheet, under the CCL tab							
Network Interruption/ Cyber Attack	An interruption of network services or VPN to laptops or unauthorized use/ cyber attack on Town networks. Includes failure of cellular service.  <ul style="list-style-type: none"> <li>terrorist &amp; vandalism actions</li> </ul>	<ul style="list-style-type: none"> <li>Ransomware</li> <li>Network Disruption</li> </ul>	<ul style="list-style-type: none"> <li>Paper backup/ flash drive of maps and forms</li> <li>Cybersecurity training</li> <li>IT test emails (phishing)</li> </ul>	<ul style="list-style-type: none"> <li>Staff complaints</li> <li>IT security measures</li> </ul>	<ul style="list-style-type: none"> <li>IT Helpdesk notification</li> <li>Revert to utilizing pen and paper or flash drive data</li> </ul>	Ballantrae/Musselman's Lake						
						No	1	4	1	6	No	None
						Stouffville						
						No	1	4	1	6	No	None



The following potential hazardous events were identified by the MECP as requirements to consider in the DWQMS Risk Assessment. Each activity or process above were reviewed against the potential hazardous events and listed below if the activity or process is impacted by the potential hazardous event.

**Long Term Impacts of Climate Change (all systems)** – Climate change trends of 10 years or greater.

**Water Supply Shortfall (all systems)** – York Region required to implement water conservation and restrictions.

**Extreme Weather Events (all systems)** – 25, 50 and 100-year storm events.

**Sustained Extreme Temperatures (all systems)** – Temperatures greater than 35 Celsius or below minus 25 Celsius for a period of 14 days or more.

**Chemical Spill impacting source water (all systems)** – Accidental chemical spills at the water supply as reported by York Region.

**Terrorist and Vandalism Actions (all systems)** – Intentional sabotage of the drinking water supply and/or distribution systems.

**Sustained pressure loss (Distribution Systems)** – Pressure in the system drops below 140 kpa (20psi) for longer than 24 hours.

**Backflow (Distribution Systems)** – Any event that causes a foreign substance to enter the water distribution system as a result of pressure gradient.

**Sudden Changes to raw water characteristics (Treatment Systems)** – Not applicable for the Ballantrae/Musselman’s Lake or Stouffville Water Distribution Systems.

**Failure of equipment or process associated with primary disinfections (Treatment Systems)** – Not applicable for the Ballantrae/Musselman’s Lake or Stouffville Water Distribution Systems.

**Failure of Equipment or process associated with secondary disinfection (Treatment Systems and Distribution Systems providing secondary disinfection)** – Not applicable for the Ballantrae/Musselman’s Lake or Stouffville Water Distribution Systems.

**Algal Blooms (Treatment Systems using Surface Water)** – Not applicable for the Ballantrae/Musselman’s Lake or Stouffville Water Distribution Systems.

**Document Change History**

Revision Number	Date	Revision Description	Revision Made By:	Revision Approved By
6	January 26, 2021	Full Risk Assessment conducted	Peter W	
7	January 26, 2022	Annual Risk Assessment Review	Peter W	Brian K
8	January 27, 2023	Annual Risk Assessment Review	Peter W	Peter W